



**EU-Declaration of Performance**

In accordance with Annex III of Regulation (EU) No.305/2011  
(Construction Product Regulation)

For the product "**HYGROSMART<sup>®</sup> BUILDING-45-THIXO**"  
**No 2085-CPR-061**

1. Unique identification code of the product-type:  
**EN 1504-3:2005**
2. Intended use:  
**EN 1504-3:2005**  
**Concrete repair product for structural repair (CC) mortar, Type R4, Class III.**
3. Manufacturer:  
**ALCHIMICA SA**  
**7, Lampsakou Str.,**  
**11528 Athens-Greece**
4. Authorized representative:  
-
5. Systems of AVCP:  
**System 2+**
6. (a) Harmonized standard:  
**EN 1504-3:2005**  
  
Notified body/dies:  
**2085**
6. (b) European Assessment Document:  
  
European Technical Assessment: **No 2085-CPR-061/07062019**  
  
Technical Assessment Body:  
**Eurotest-Control EAD**  
**108 Besarabia St. 1517 Sofia Bulgaria**  
  
Notified body:  
**2085**

7. Declared performance

**EN 1504-3:2005**

Performance determined of **HYGROSMART® BUILDING-45-THIXO**

<b>Essential characteristics</b>	<b>Performance</b>	<b>Requirement</b>	<b>Harmonized technical specification</b>
Capillary absorption	0.05 kg/m <sup>2</sup> .h <sup>0,5</sup>	<0.5	EN 1504-3:2005
Compressive strength	49.6 N/mm <sup>2</sup>	≥45	
Chloride ion content	<0.01%	≤0.05	
Adhesive bond	2.9 N/mm <sup>2</sup>	≥2.0	
Thermal compatibility	2.4 N/mm <sup>2</sup>	≥2.0	
Carbonation resistance	pass	d <sub>k</sub> ≤control concrete MC (0,45) for class R4	

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Krimizis Christos  
CEO

Athens 07012020