Alchimica S.A

7 Lampsakou Street Athens 115 28



Agrément Certificate 18/5567

Product Sheet 1

Tel: +30 214 4167 700 Fax: +30 210 5619 287

e-mail: alchimica@alchimica.com website: www.alchimica.com

ALCHIMICA ROOF WATERPROOFING SYSTEM

HYPERDESMO

This Agrément Certificate Product Sheet⁽¹⁾ relates to Hyperdesmo, a liquid-applied, moisture activated polyurethane for use on new and existing flat and pitched roofs with limited access.

(1) Hereinafter referred to as 'Certificate'.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- · design considerations
- · installation guidance
- regular surveillance of production
- formal three-yearly review.

KEY FACTORS ASSESSED

Weathertightness — the system will resist the passage of moisture into the building (see section 6).

Properties in relation to fire — the system can enable a roof to be unrestricted under the national Building Regulations (see section 7).

Adhesion — the adhesion of the system is sufficient to resist the effects of any likely wind suction and the effect of thermal or other minor movement likely to occur in practice (see section 8).

Resistance to foot traffic — the system, when applied with Hyperdesmo-Ady top coat, will accept without damage the limited foot traffic and loads associated with installation and maintenance (see section 9).

Durability — under normal service conditions and when used under protection or in non-accessible areas, the system will provide a durable waterproof covering with a service life of at least 25 years (see section 11).

The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of First issue: 28 August 2018 John Albon – Head of Approvals

Construction Products

Claire Custis- Monas

Claire Curtis-Thomas
Chief Executive

The BBA is a UKAS accredited certification body – Number 113.

The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Board of Agrément

Bucknalls Lane Watford Herts WD25 9BA

©2018

tel: 01923 665300 clientservices@bbacerts.co.uk www.bbacerts.co.uk

Regulations

In the opinion of the BBA, Hyperdesmo, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement:

B4(2) External fire spread

Comment:

On suitable substructures, the use of the system can enable a roof to be unrestricted under this Requirement. See section 7 of this Certificate.

Requirement:

C2(b) Resistance to moisture

Comment:

The system will contribute to satisfying this Requirement. See section 6.1 of this

Certificate.

Regulation: Comment: 7 Materials and workmanship

The system is acceptable. See section 11 and the Installation part of this

Certificate.



Comment:

The Building (Scotland) Regulations 2004 (as amended)

Regulation: 8(1)(2

8(1)(2) Durability, workmanship and fitness of materials

Use of the system satisfies the requirements of this Regulation. See sections 10.1

and 11 and the Installation part of this Certificate.

Regulation:

9 Building standards applicable to construction

Standard: Comment:

2.8 Spread from neighbouring buildings.

The system, when applied to a non-combustible substrate, can be regarded as

having low vulnerability under clause 2.8.1(1)(2) of this Standard. See section 7 of

this Certificate.

Standard: Comment:

3.10

Precipitation

The use of the system will enable a roof to satisfy the requirements of this

Standard, with reference to clauses 3.10.1 $^{(1)(2)}$ and 3.10.7 $^{(1)(2)}$. See section 6.1 of

this Certificate.

Standard:

Comment:

7.1(a) Statement of sustainability

The system can contribute to meeting the requirements of Regulation 9,

Standards 1 to 6 and therefore will contribute to a construction meeting a bronze

level of sustainability as defined in this Standard.

Regulation Comment:

12

Building standards applicable to conversions

All comments given for the system under Regulation 9, Standards 1 to 6 also apply

to this Regulation, with reference to clause $0.12.1^{(1)(2)}$ and Schedule $6^{(1)(2)}$.

(1) Technical Handbook (Domestic).

(2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation:

23(a)(b)(i) Fitness of materials and workmanship

Comment: The system is acceptable. See section 11 and the *Installation* part of this

Certificate.

Regulation:

28(b) Resistance to moisture and weather

Comment: The use of the system will enable a roof to satisfy the requirements of this

Regulation. See section 6.1 of this Certificate.

Regulation:

36(b) External fire spread

Comment:

On suitable substructures, the use of the system can enable a roof to be unrestricted under the requirements of this Regulation. See section 7 of this

Certificate.

Construction (Design and Management) Regulations 2015 Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

See section: 3 *Delivery and site handling* of this Certificate.

Additional Information

NHBC Standards 2018

In the opinion of the BBA, Hyperdesmo, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapter 7.1 *Flat Roofs and balconies*.

CE marking

The Certificate holder has taken the responsibility of CE marking the system, in accordance with European Technical Assessment 04/0082, issued by Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc) under ETAG 005 : 2000, Parts 1 and 6. An asterisk (*) appearing in this Certificate indicates that data shown are given in the manufacturer's Declaration of Performance.

Technical Specification

1 Description

- 1.1 Hyperdesmo is a liquid applied roof waterproofing kit which consists of:
- Hyperdesmo a one component, polyurethane, liquid applied waterproofing membrane
- Hyperdesmo-Ady a one component, liquid applied, aliphatic polyurethane top coat for use over Hyperdesmo.
- $1.2 \ \ The \ level \ of \ Use \ Categories, as \ defined \ in \ ETAG \ 005: 2004, are \ as \ detailed \ in \ Table \ 1 \ of \ this \ Certificate.$

Table 1	Classification of Use Categories to ETAG 005: 200)4

	Hyperdesmo	Hyperdesmo + Hyperdesmo-Ady	
Working life	W3 (25 years)	W2 (10 years)	
Climatic zone	S (Severe climate)		
Imposed load	P1	Р3	
Roof slopes	S1-S4 (<5% to > 30%)		
Surface temperature use	Lowest TL3 (-20°C)		
	Highest TH4 (90°C)	Highest TH3 (80°C)	

- 1.3 Ancillary products used with the system, but outside the scope of this Certificate, are:
- Aquadur a two-component water based epoxy primer for use on concrete substrates
- Geotextile Alchimica a non-woven polyester reinforcement for use in the reinforcement of construction details, flashing joints, cracks and gaps.

2 Manufacture

- 2.1 The system components are manufactured by blending raw materials.
- 2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:
- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- · monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.
- 2.3 The management system of Alchimica S.A has been assessed and registered as meeting the requirements of EN ISO 9001 : 2015 by BVQA (Certificate GR17.2821Q).

3 Delivery and site handling

- 3.1 The Hyperdesmo component is available in 1, 6, 15, 25 and 200 kg drums. It must be stored in a dry location within a temperature range of 5 to 25°C. The product has a shelf life of a minimum of 12 months.
- 3.2 Hyperdesmo-Ady is available in 1, 4 and 20 litre tins. It must be stored in a dry location within a temperature range of 5 to 20°C. The product has a shelf life of a minimum of 12 months.
- 3.3 The Certificate holder has taken responsibility of classifying and labelling the system components under the *CLP Regulation (EC) No 1272/2008 on the classification, labelling and packaging of substances and mixtures.* Users must refer to the relevant Safety Data Sheet(s).

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Hyperdesmo.

Design Considerations

4 Use

- 4.1 Hyperdesmo, when used with Hyperdesmo-Ady top coat, is satisfactory for use as a waterproofing system on new and existing flat and pitched limited access roofs. When installed without the top coat, the system is only suitable for non-accessible areas or under protection.
- 4.2 The system is suitable for use on the following substrates:
- concrete
- mortar
- fibre cement.
- 4.3 Limited access roofs are defined for the purpose of this Certificate as those subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc. Where traffic in excess of this is envisaged, additional protection to the membrane must be provided (see section 9).
- 4.4 Flat roofs are defined for the purpose of this Certificate as those having a minimum finished fall of 1:80. Pitched roofs are defined as those having falls in excess of 1:6.
- 4.5 When designing flat roofs, twice the minimum finished fall should be assumed unless a detailed analysis of the roof is available, including overall and local deflection, direction of falls etc.

4.6 Decks to which the system is to be applied must comply with the relevant requirements of BS 6229 : 2003, BS 8217 : 2005 and, where appropriate, *NHBC Standards* 2018, Chapter 7.1.

5 Practicability of installation

Installation of the system must be carried out by specialist roofing contractors trained and approved by the Certificate holder.

6 Weathertightness



- 6.1 The system will adequately resist the passage of moisture to the inside of the building and so comply with the relevant requirements of the national Building Regulations.
- 6.2 The system is impervious to water and, when used in accordance with this Certificate, will give a weathertight roofing capable of accepting minor movement without damage.

7 Properties in relation to fire



- 7.1 When tested to CEN/TS 1187 : 2012 : Test 4 and classified in accordance with BS EN 13501-5 : 2016, a system comprising a 8 mm fibre cement board, a base coat of Hyperdesmo and a top coat of Hyperdesmo reinforced with geotextile (134 g/m 2), achieved a classification of B_{ROOF}(t4).
- 7.2 The designation of other specifications, eg when used on combustible substrates, should be confirmed by:

England and Wales – test or assessment in accordance with Approved Document B, Appendix A, clause 1 **Scotland** – test to conform to Mandatory Standard 2.8, clause 2.8.1⁽¹⁾⁽²⁾

- (1) Technical Handbook (Domestic).
- (2) Technical Handbook (Non-Domestic).

Northern Ireland – test or assessment by a UKAS-accredited laboratory, or an independent consultant with appropriate experience.

8 Adhesion

The adhesion of the system to the substrates indicated in section 4.2 is sufficient to resist the effect of any wind suction, elevated temperatures, thermal shock or minor movement likely to occur in service.

9 Resistance to foot traffic

- 9.1 The system, when applied with Hyperdesmo-Ady top coat, can accept without damage the limited foot traffic and light concentrated loads associated with installation, maintenance and pedestrian traffic. However, reasonable care should be taken to avoid puncture by sharp objects or concentrated loads.
- 9.2 When applied without the top coat, the system must only be accessed when a suitable protection, such as pavers, is used.

10 Maintenance



- 10.1 The system must be the subject of annual inspections and maintenance to ensure continued performance, in line with good practice.
- 10.2 Where damage has occurred it should be repaired in accordance with section 15 and the Certificate holder's instructions.

11 Durability



Hyperdesmo will achieve an initial life expectancy of at least 25 years when used under protection or in non-accessible areas. Hyperdesmo-Ady top coat may require re-application after 10 years.

Installation

12 General

- 12.1 The system must be applied when the air and substrate temperature are greater than 5°C. The advice of the Certificate holder should be sought where air temperatures exceed 35°C.
- 12.2 Detailing (eg upstands) is carried out in accordance with the Certificate holder's instructions.

13 Site and surface preparation

- 13.1 Substrates on which the system is applied must be properly prepared in accordance with the Certificate holder's instructions.
- 13.2 Adhesion to substrates will depend on the conditions and cleanness of the substrate. Substrates must be visibly dry, sound and free from loose materials or contamination (eg moss and algae).
- 13.3 The surface must be prepared to remove loose or flaking materials, ideally with a high pressure washer, but the substrate must be visibly dry before the application of the system.
- 13.4 Damaged areas of the substrate must be removed, replaced or repaired. Substrate defects (eg shallow-bottomed cracks and indentations) are filled in accordance with the Certificate holder's instructions.
- 13.5 Deck surfaces must be free from sharp projections, such as protruding fixing bolts and concrete nibs.
- 13.6 Gutters and outlets must be checked to ensure that they are, and remain, clear of all debris.
- 13.7 All points of potential weakness such as splits, cracks, joints and crazed surfaces must be reinforced with Geotextile Alchimica prior to the application of the system.
- 13.8 Aquadur primer can be used to prime concrete substrates. The primer should be applied at a rate of 200 g·m $^{-2}$. Any ponding water should be removed before application of the primer.

14 Application

- 14.1 Prior to application, checks must be made to ensure the substrate is dry (ie free from rainwater, surface condensation and frost) and that the prevailing weather and site conditions are correct. The following normal limitations apply:
- application must not take place when the relative humidity is in excess of 95%, or in fog. The temperature/humidity must be such that there is no risk of surface condensation occurring before or during application
- the substrate temperature must be 3°C above the measured due point
- the primer, where used, must be cured
- the wind speed must be such that it does not interfere with the application and cause overspray.
- 14.2 Application of Hyperdesmo can be by brush, roller or spray in at least two coats. The first coat is applied at a coverage rate of 0.7 to 0.9 kg·m⁻², the second coat is applied at a rate of 0.8 to 0.9 kg·m⁻². The minimum total consumption is 1.5 to 1.8 kg·m⁻², to give a minimum total thickness of 0.95 to 1 mm.
- 14.3 The second coat must be applied less than 48 hours after the first application.

14.4 For additional protection for use of the system in accessible roofs up to user load P3, a top coat of Hyperdesmo-Ady should be applied at a coverage rate of 0.2 to 0.4 kg·m² in one to two successive coats over a cured Hyperdesmo surface.

15 Repair

The repair of minor damage to the system can be achieved effectively by cleaning back to unweathered material and recoating the damaged area with the membrane at the application rates stated in section 14.2.

Technical Investigations

16 Tests

16.1 Tests were carried out in accordance with ETAG 005 : 2000, Parts 1 and 6, and the results assessed by the BBA to determine:

- · tensile strength and elongation
- water vapour diffusion resistance coefficient (μ)
- watertightness
- · tensile bond strength on concrete, ceramic and fibre cement
- dynamic indentation
- static indentation
- resistance to fatigue movement
- resistance to UV ageing, followed by tensile strength and dynamic indentation
- resistance to water exposure, followed by tensile bond strength and static indentation
- resistance to heat ageing, followed by tensile bond strength and static indentation.

16.2 Characterisation tests were conducted on the liquid components as follows:

Hyperdesmo

- density
- dry extract
- ash content
- viscosity

Hyperdesmo-Ady

- density
- viscosity.

17 Investigations

- 17.1 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of the materials used.
- 17.2 Data on the fire performance were evaluated.

Bibliography

BS 6229 : 2003 Flat roofs with continuously supported coverings — Code of practice

BS 8217 : 2005 Reinforced bitumen membranes for roofing — Code of practice

BS EN 13501-5 : 2016 Fire classification of construction products and building elements — Classification using data from external fire exposure to roofs tests

EN ISO 9001 : 2015 Quality management systems — Requirements

ETAG 005: 2000, Part 1 Liquid Applied Roof Waterproofing Kits — General

ETAG 005: 2000, Part 6 Liquid Applied Roof Waterproofing Kits — Specific stipulations for Kits based on Polyethurane

Conditions of Certification

18 Conditions

18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page no other company, firm, organisation or person may hold claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

18.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

18.5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

18.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.

British Board of AgrémentBucknalls Lane
Watford
Herts WD25 9BA

tel: 01923 665300 clientservices@bbacerts.co.uk www.bbacerts.co.uk